



**CITY OF ILWACO**  
**City Center Reservoir Project Workshop**  
**Tuesday, May 27, 2014**

**A. Call to Order**

Mayor Cassinelli called the workshop to order at 5:14 p.m.

**B. Present:** Councilmembers: Fred Marshall, Jon Chambreau, Gary Forner and David Jensen (arrived at 5:35); City Engineer Nancy Lockett, Gray & Osborne; Citizens: Tom Williams; Deputy City Clerk Ariel Smith

**C. 500,000-Gallon Reservoir Project**

1. Mayor Cassinelli started the meeting off with a description of the issue at hand. There was a miscalculation in the survey by G&O which caused the overflow of the new reservoir to be approximately 3 feet lower than originally planned. However, this does not change the fact that the reservoir still has a capacity of 500,000 gallons. What it does affect, is the existing steel reservoir from reaching its capacity. At this time there have been multiple solutions thrown around and various ideas on how to resolve this issue. Nancy presented what G&O thought would be the best solution, to install a 10-inch extension to the overflow riser in the glass-fused reservoir. She also presented the other two options, increasing the maximum operating level elevation and installing an altitude valve. There was a lot of discussion around this suggestion, and a lot of talk about other compensation that G&O could possibly provide the City. Nancy suggested that they could also do the specs for painting the existing tank. This item was then added to the regular meeting agenda as a walk on.

2. Next meeting: Added to the regular meeting agenda as a discussion item.

**D. Adjournment**

Mayor Cassinelli adjourned the workshop at 6:02 p.m.

---

Mike Cassinelli, Mayor

---

Ariel Smith, Deputy City Clerk